

## Laminar Pack Static Oil Separators

### 1 Dimensions

TYPE S-II-I UNI EN 858		EXTERNAL DIMENSIONS			LAMINAR OIL SEPARATOR (A)	PEDESTRIAN COVER load 200 kg/m <sup>2</sup> (B)		(A) + (B)	LIGHT TRAFFIC VEHICLE COVER load 2,000 kg/m <sup>2</sup> (C)		(A) + (C)	HEAVY TRAFFIC VEHICLE COVER load 7,000 kg/m <sup>2</sup> (D)		(A) + (D)
Code	Nominal dimensions l/s	Width cm	Length cm	Height cm	Weight 100 kg	Thickness cm	Weight 100 kg	Weight 100 kg	Thick- ness cm	Weight 100 kg	Weight 100 kg	Thickness cm	Weight 100 kg	Weight 100 kg
DIS-01	NS 10	160	250	250	74	10	9	83	16	14	88	20	18	92
DIS-02	NS 20	160	290	250	80	10	10	90	16	17	97	20	20	100
DIS-03	NS 40	250	325	250	115	10	19	134	16	31	146	20	38	153
DIS-04	NS 50	250	400	250	137	10	23	160	16	38	175	20	46	183
DIS-05	NS 65	250	450	250	150	10	26	176	16	43	193	20	52	202
DIS-06	NS 80	250	550	250	174	10	32	206	16	52	226	20	64	238
DIS-07	NS 100	250	650	250	195	10	38	233	16	62	257	20	76	271
DIS-08	NS 120	250	750	250	225	10	44	269	16	72	297	20	88	313
DIS-09	NS 150	250	950	250	270	10	56	326	16	92	362	20	114	384
DIS-10	NS 200	250	1017	252	300	10	61	361	16	98	398	20	122	422

All the products in the table are **CE** marked

**Please contact our Sales Office if you require larger treatment plants.**

The pedestrian covers are fitted with class B125 cast iron inspection covers.

The vehicle covers for light traffic are fitted with class C250 cast iron inspection covers.

The vehicle covers for heavy traffic are fitted with class D400 cast iron inspection covers.

The foundation slab must be at least 20 cm thick and be reinforced with a double electrically welded steel mesh, 8 mm diameter, 20x20 cm mesh.

A 3-5 cm layer of sand must be laid on the foundation slab where the prefabricated elements will be placed.