

Extended Aeration Activated Sludge Treatment Plants

2 Spare machinery, Lifting station, Technical room

SPARE MACHINERY				WASTEWATER LIFTING STATION							TECHNICAL ROOM				
Code	submersible PUMP (lifting) kw installed	Code	air BLOWER (minibioxy/ bcs) kw installed	Code	Width cm	Length cm	Height cm	Weight 100 kg		Kw. instal.	Code	Width cm	Length cm	Height cm	Weight 100 kg
								pedestrian cover 200 kg/m ²	vehicle cover 7,000 kg/m ²						
MBP-01	1,30	MBS-01	1,10	MBST-01	140	160	260/270	50	55	1,30	MBG-01	150	82	140	16
MBP-02	1,30	MBS-02	1,10	MBST-02	140	160	260/270	50	55	1,30	MBG-02	150	82	140	16
MBP-03	1,30	MBS-03	1,10	MBST-03	140	160	260/270	50	55	1,30	MBG-03	150	82	140	16
MBP-04	1,30	MBS-04	1,10	MBST-04	140	160	260/270	50	55	1,30	MBG-04	150	82	140	16
MBP-05	1,30	MBS-05	1,50	MBST-05	140	160	260/270	50	55	1,30	MBG-05	140	160	260	50
MBP-06	1,30	MBS-06	1,50	MBST-06	140	160	260/270	50	55	1,30	MBG-06	140	160	260	50
MBP-07	1,30	MBS-07	1,50	MBST-07	140	160	260/270	50	55	1,30	MBG-07	140	160	260	50
MBP-08	1,30	MBS-08	2,20	MBST-08	140	160	260/270	50	55	1,30	MBG-08	140	160	260	50
MBP-09	1,30	MBS-09	2,20	MBST-09	160	180	260/270	60	68	1,30	MBG-09	140	160	260	50
MBP-10	1,30	MBS-10	2,20	MBST-10	160	180	260/270	60	68	1,30	MBG-10	140	160	260	50
MBP-11	1,30	MBS-11	4,00	MBST-11	160	250	260/270	74	83	1,30	MBG-11	140	160	260	50
MBP-12	1,30	MBS-12	4,00	MBST-12	160	250	260/270	74	83	1,30	MBG-12	140	160	260	50

Please contact our Sales Office if you require larger treatment plants.

The pedestrian covers are fitted with class B125 cast iron or galvanised steel sheet inspection covers.

The vehicle covers are fitted with class C250/D400 cast iron inspection covers.

The foundation slab must be at least 20 cm thick and be reinforced with a double electrically welded steel mesh, 8 mm diameter, 20x20 cm mesh.

A 3-5 cm layer of sand must be laid on the foundation slab where the prefabricated elements will be placed.

All dimensions of the prefabricated elements are indicative.

Gazebo S.p.A. allows a tolerance of a few centimetres.