

Water pressurisation plants

2 Technical Room

TYPE	EXTERNAL DIMENSIONS		
	Code	Width cm	Length cm
G-07	200	250	250
G-08	250	250	250
G-09	250	325	250
G-10	250	400	250
G-11	250	450	250
G-12	250	550	250
G-13	250	650	250
G-14	250	750	250
G-15	250	950	250
G-16	250	1017	250

Please contact our Sales Office if you require larger sizes.

The pedestrian covers are fitted with class B125 cast iron inspection covers.

The vehicle covers for light traffic are fitted with class C250 cast iron inspection covers.

The vehicle covers for heavy traffic are fitted with class D400 cast iron inspection covers.

The foundation slab must be at least 20 cm thick and be reinforced with a double electrically welded steel mesh, 8 mm diameter, 20x20 cm mesh.

A 3-5 cm layer of sand must be laid on the foundation slab where the prefabricated elements will be placed.